Intraday Process

Differences between the current and the new system

➡ There is no need for operators permission for nomination (access gate)

➡ No more code 34X-DEBALANS --- H. The trader can remain unbalanced in the intraday process and nominate a new schedules.

➡ There are no partially accepted schedules. The system processes or rejects the entire schedules (BRS) during the nomination.

➡ Matching cycles

➡ Cut-off matching cycles (automatic or manual)

Intraday Process

Way of works on borders

- ➡ borders working in sessions (RO,HU)

- ➡ borders working in flowing blocks (AL,MK,HU,ME,BA i HR)

- ➡ Ther is no intraday on BG border

JOINT STOCK COMPANY
ELEKTROMREŽA SRBIJE

Nomination Gates in Intraday Process

Borders working in sessions:

- 6 session, 4 block hours

- Balance Responsible Parties will be able to alocated ID capacity from 18:00 CET in D-1 for D, but no later then 150 minutes before first hour of the session.

- Balance Responsible Parties will be able to submit their Balance Responsible Schedules from 18:00 CET in D-1 for D, but no later then 90 minutes before first hour of the session.

- It is possible to nominate without ID capacity in the system. Nominated TS (time series) must contain the correct capacity alocation identification (CAI), otherwise TS will be reduced to the zero in the cutoff cycle.

Nomination Gates in Intraday Process

➡ The capacity from the allocation platform enters the system at the latest 140 minutes before the beginning of the session.

Nomination Gates in Intraday Process

Borders working in flowing blocks:

- Balance Responsible Parties will be able to alocated ID capacity from 18:00 CET in D-1 for D, but no later then 120 minutes before first hour with change with the exception on BA border where it is 90 minutes.

- Balance Responsible Parties will be able to submit their Balance Responsible Schedules from 18:00 CET in D-1 for D, but no later then 60 minutes before first hour with change.

- Checking of the Capacity Contracts will be done immediately while submitting Balance Responsible Schedules.

JOINT STOCK COMPANY
ELEKTROMREŽA SRBIJE

Nomination Gates in Intraday Process

- Balance Responsible Parties will be able to submit their internal transaction, Consumption Responsible Schedules and Production Responsible Schedule from 18:00 CET in D-1 for D, but no later then 60 minutes before first hour with change.

- Checking of the internal mismatch and imbalance(Matching cycle) will be performed every hour for every 15 minutes (00,15,30 and 45min).

JOINT STOCK COMPANY
ELEKTROMREŽA SRBIJE

Matching process in Intraday Process

- Matching process will be carried through Matching cycles.

- Matching cycles lasts 5 minutes max. During the matching cycle, the system does not send notification to the traders (ACK, CNF).

- For borders working in flowing blocks there are three Matching cycles per each hour and one Cut-off Matching cycle. In case of mismatch, cut-off will be performed 45 minutes before first hour with change.

- For borders working in sessions there are three Matching cycles per each hour and one Cut-off Matching cycle. In case of mismatch, cut-off will be performed 45 minutes before the first hour of session.

JOINT STOCK COMPANY
ELEKTROMREŽA SRBIJE

Matching process in Intraday Process

- Once confirmed Time Series with external nominations cannot be changed.

- Time Series Confirmation will be created for every border separately after successful matching within Matching cycle.

Internal Matching in Intraday Process

- There are four Internal Matching cycles per hour (00, 15, 30 and 45 min).

- The cut-off Internal Matching cycle is set 45 minutes before the first hour with a change.

- In case of matching, the system issues a positive CNF file. In the case of mismatch, the system issues a Anomaly file.

- After receiving first Anomaly, next one will be initiated after every change of internal mismatch during next Internal Matching Gate.

JOINT STOCK COMPANY
ELEKTROMREŽA SRBIJE

Questions?

JOINT STOCK COMPANY
ELEKTROMREŽA SRBIJE

Thank you for your attention!

JOINT STOCK COMPANY
ELEKTROMREŽA SRBIJE