



Agenda

- Amendments of Grid Code (30 minutes)
- Amendments of Market Code (30 minutes)
- Practical Scheduling training – Day Ahead
- Free time 12:00 – 12:30
- Practical Scheduling training – Intraday
- Miscellaneous

Amendments of Grid Code

Market Division

Belgrade, September 2014.



ЈАВНО ПРЕДУЗЕЋЕ
ЕЛЕКТРОМРЕЖА СРБИЈЕ

Document history

Version No.	Date of creation	Date of issuing AERS approvals	Description of changes
1.0	15.04.2008.	17.04.2008.	
	19.12.2011.	23.12.2011.	Amendments to the Grid Code, in the part referring to technical requirements for connection and access to the system
2.0	19.06.2014.	18.07.2014.	Compliance with the Energy Law and the Electricity Market Rules of Procedure

Improvements

- Schedule declaration
- Imbalance
- Decimal values
- Defining new EIC code
- Energy balance



Schedule declaration

- Grid code defines time frames and the protocols which Parties follow during Schedule declaration
- How to submit a schedule in day ahead process?
- How to submit a schedule in intraday process?

Imbalance

- Daily schedule could be unbalanced after gate closure of Day ahead process
- Possibility to balance daily schedule in intraday process
- Balance responsibility

Decimal values

- Possibility to submit decimal values (internal transactions, consumption, production)
- Maximum number of digits to the right of the decimal point is 3



New EIC code

- TRPs must submit balanced schedule
- 34X-DEBALANS---H
- TRPs which want to stay unbalanced submit Time Series with this party



Energy balance

- JP EMS has an obligation to submit necessary data for creation of Energy balance to Ministry of Energy
- In order to complete Energy balance, JP EMS will require the data from BRP
- The form will be available on our website